

Protective Rubber Equipment Labeling Chart

for Salisbury Natural Rubber and SALCOR® Rubber Protective Equipment

Class Color	Proof Test Voltage AC / DC	Max. Use Voltage* AC / DC	Rubber Molded Products Label	Insulating Rubber Glove Label	Insulating Rubber Dipped Sleeve Label
00 Beige	2,500 / 10,000	500 / 750			
0 Red	5,000 / 20,000	1,000 / 1,500			
1 White	10,000 / 40,000	7,500 / 11,250			
2 Yellow	20,000 / 50,000	17,000 / 25,500			
3 Green	30,000 / 60,000	26,500 / 39,750			
4 Orange	40,000 / 70,000	36,000 / 54,000			

ASTM Specification Reference

D120	Rubber Insulating Gloves	F1742	PVC Insulating Sheeting
D178	Rubber Insulating Matting	F2320	Rubber Insulating Sheeting
D1048	Rubber Insulating Blankets	F2677	Electrically Insulating Aprons
D1049	Rubber Insulating Covers	Type I-	Designates natural rubber.
D1050	Rubber Insulating Line Hose	Type II-	Designates SALCOR® UV and ozone resistant rubber.
D1051	Rubber Insulating Sleeves	* Max. Use Voltage when worn with leather protectors.	
F478	In-Service Care of Line Hose & Covers	Insulating Gloves and Sleeves must have a color coded label to meet appropriate ASTM Specifications.	
F479	In-Service Care of Insulating Blankets		
F496	In-Service Care of Gloves & Sleeves		
F696	Leather Protectors for Insulating Gloves and Mittens		
F1236	Inspection Guide for Rubber Products		

SALISBURY
by Honeywell